



# कार्यालय नगर निगम ग्रेटर जयपुर

(पण्डित दीनदयाल उपाध्याय भवन, लालकोठी, टॉक रोड जयपुर-302015, राजस्थान)



आज़ादी का  
अमृत महोत्सव

क्रमांक :- एफ.31( )मुख्य स्वा.अधि. / ननिज / 2024 / 331

दिनांक :- 22-04-24

## SAFE DRINKING WATER AND SANITARY CONDITIONS CERTIFICATE

It is certified that an inspection team headed by **Dr. Rashmi Kankaria**, **Cheif Health Officer** from **Nagar Nigam Jaipur Greater** inspected the **Mahaveer Public School** and found that **Mahaveer Public School, Vardhman Path, Mahaveer Marg, C-Scheme, Jaipur** has safe drinking water facilities for the students and members of staff of the institution, School is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central / State / U.T.Govt.

The Certificate is valid upto 31 March, 2025.

( **Dr. Rashmi Kankaria** )  
Cheif Health Officer  
Nagar Nigam Jaipur Greater

To,

**The Principal,**  
**Mahaveer Public School,**  
Vardhman Path, Mahaveer Marg, C-Scheme, Jaipur



**OFFICE OF THE CHIEF CHEMIST**  
**PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR**

**REPORT OF THE CHEMICAL EXAMINATION OF WATER**

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2024-2025/

340

Date: 25/04/2024

To,

Principal

Mahaveer Public School

C. Scheme , Jaipur

Not Valid for water  
quality Legal Cases

The Sample was not Collected  
by this Laboratory

Date of Receipt: 23.04.2024

Particulars			RO Water Mahaveer Public School
value as per I.S.:10500/2012			
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			22.04.20214
Lab. Sample No.			P-34
1. pH	6.5-8.5	6.5-8.5	7.47
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	80
6. Total Hardness (as CaCo3) mg/l	200	600	100
7. Calcium (as Ca) mg/l	75	200	16
8. Magnesium (as Mg) mg/l	30	100	14
9. Chloride (as Cl-) mg/l	250	1000	20
10. Nitrates (as NO3-) mg/l	45	45	2
11. Sulphate (as SO4-2) mg/l	200	400	4
12. Total Dissolved Solids mg/l	500	2000	140
13. Fluoride mg/l	1.00	1.5	0.12
14. Iron mg/l	1.0	No Relaxation	Nil
15. Arsenic mg/l	0.01	No Relaxation	Nil

Remark:- 1. All chemical parameters except pH are in mg/L  
2. Tested Results Relate only to The Samples send by you

*(Signature)*  
25/4/2024

Superintending Chemist (Heavy Metal)  
P.H.E.D. Laboratory, Jaipur

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2024-2025/

Copy to:-

1.The Chief Chemist, PHED Raj. Jaipur

Superintending Chemist (Heavy Metal)  
P.H.E.D. Laboratory, Jaipur