



कार्यालय नगर निगम ग्रेटर, जयपुर

(पण्डित दीनदयाल उपाध्याय भवन, लालकांठी, टोंक रोड जयपुर-302015, राजस्थान)

क्रमांक :- एफ.31()मु.स्वा.अधि./ननिज/2025/72

दिनांक :- 26-5-25

SAFE DRINKING WATER AND SANITARY CONDITIONS CERTIFICATE

It is certified that an inspection team headed by **Dr. Rashmi Kankaria, Chief Health Officer** from Nagar Nigam Greater, Jaipur inspected the **MAHAVEER PUBLIC SCHOOL Vardhman Path Mahaveer Marg C-Scheme, Jaipur** on 16-04-2025 and on the basis of the Water Test Report (Attached) bearing no 562 dated 15-05-2025 certified that the **MAHAVEER PUBLIC SCHOOL** has safe drinking water facilities for the students and members of staff of the institution, School is maintaining the hygienic sanitation condition in the building & the campus as per the norms prescribed by the Central/State/U.T.Govt.

The Certificate is valid upto 31 March. 2026.

(**Dr. Rashmi Kankaria**)
Chief Health Officer
Nagar Nigam Greater Jaipur

To,

The Principal,
MAHAVEER PUBLIC SCHOOL
Vardhman Path Mahaveer Marg C-Scheme, Jaipur

D/Dr.Rashmi Kakariya/ All Letter



Signature valid

Digitally signed by Rashmi Kankaria
Designation: Chief Health Officer
Date: 2025.05.23 15:54:34 IST
Reason: Approved

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2025-2026/ 562


Date: 15/5/2025

To,
Principal
Mahaveer Public School,
Vardhman path Mahaveer marg,
C Scheme Jaipur.

Date of Receipt-12.05.25

Particulars			RO Water Mahaveer Public School,
	value as per I.S.:10500/2012		
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			12-05.2025
Lab. Sample No.			P-27
1. pH	6.5-8.5	6.5-8.5	6.87
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	50
6. Total Hardness (as CaCo3) mg/l	200	600	60
7. Calcium (as Ca) mg/l	75	200	8
8. Magnesium (as Mg) mg/l	30	100	9
9. Chloride (as Cl-) mg/l	250	1000	10
10. Nitrates (as NO3-) mg/l	45	45	2
11.Sulphate(as So4- 2)mg/l	200	400	2
12. Total Dissolved Solids mg/l	500	2000	140
13.Fluoride mg/l	1.00	1.5	0.08
14.Iron mg/l	1.0	No Relaxation	Nil
15.Arsenic mg/l	0.01	No Relaxation	Nil

Remark- 1. All chemical parameters except pH are in mg/L
2. Tested Results Relate only to The Samples send by you


Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2025-2026/

Date:

Copy to:- 1. The Chief Chemist, PHED Raj. Jaipur

Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur