



कार्यालय नगर निगम जयपुर

(पण्डित दीनदयाल उपाध्याय भवन, लालकोठी, टॉक रोड जयपुर-302015, राजस्थान)

क्रमांक :- एफ.31 ()मु.स्वा.अधि./ननिज/2026-27/ 99

दिनांक :- 18-05-2026

SAFE DRINKING WATER AND SANITARY CONDITIONS CERTIFICATE

It is certified that an inspection team headed by **Dr. Rashmi Kankaria, Chief Health Officer** from **Nagar Nigam Jaipur** inspected the **MAHAVEER PUBLIC SCHOOL, Vardhman Path Mahaveer Marg C-Scheme, Jaipur** on 15-05-2026 and on the basis of the Water Test Report (Attached) bearing no 448-449 dated 28-04-2026 certified that the **MAHAVEER PUBLIC SCHOOL**, has safe drinking water facilities for the students and members of staff of the institution, School is maintaining the hygienic sanitation condition in the building & the campus as per the norms prescribed by the Central/State/U.T.Govt.

The Certificate is valid upto 31 March. 2027.

(Dr. Rashmi Kankaria)
Chief Health Officer
Nagar Nigam Jaipur

To,

The Principal,
MAHAVEER PUBLIC SCHOOL
Vardhman Path Mahaveer Marg C-Scheme, Jaipur

PRINCIPAL

Mahaveer Public School
JAIPUR

Secretary

Mahaveer Public School

Signature valid

Digitally signed by Rashmi Kankaria
Designation : Chief Health Officer
Date: 2026.05.18 13:32:32 IST
Reason: Approved

D/Dr.Rashmi Kakariya/All Letter

RajKaj Ref No.:
22295237

M e-Sign



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2026-2027/ 448-449

Date: 22/4/26

To,

Principal
 Mahavee Public School
 Vardhaman Path Mahaveer Marg
 C Scheme Jaipur

Not Valid for water
 quality / Legal Cases

The Sample was not Collected
 by this Laboratory

Your Letter 103 Dated 20/04/2026
 Date of Receipt 22/04/2026

| Particulars | | | RO Water Mahavee Public School Vardhaman Path Mahaveer Marg C Scheme Jaipur |
|------------------------------------|-----------------------------------|--|--|
| value as per I.S.:10500/2012 | | | |
| Village / Town | Requirement (Acceptable Limit) | Permissible Limit in the absence of Alternate Source | Jaipur |
| Date of Collection | | | 22/04 /2026 |
| Date of Examination | | | 22/04 /2026 |
| Lab. Sample No. | | | P-26 |
| 1. pH | 6.5-8.5 | 6.5-8.5 | 6.83 |
| 2. Turbidity (NTU) | 1 | 5 | Nil |
| 3. Colour (Hazen units) | 5 | 15 | None |
| 4. Odour | Un Objectionable | | U.O |
| 5. Total Alkalinity(as CaCo3) mg/l | 200 | 600 | 40 |
| 6. Total Hardness (as CaCo3) mg/l | 200 | 600 | 100 |
| 7. Calcium (as Ca) mg/l | 75 | 200 | 24 |
| 8. Magnesium (as Mg) mg/l | 30 | 100 | 10 |
| 9. Chloride (as Cl-) mg/l | 250 | 1000 | 120 |
| 10. Nitrates (as NO3-) mg/l | 45 | 45 | 2 |
| 11. Sulphate(as So4-2)mg/l | 200 | 400 | 4 |
| 12. Total Dissolved Solids mg/l | 500 | 2000 | 252 |
| 13. Fluoride mg/l | 1.00 | 1.5 | 0.21 |
| 14. Iron mg/l | 1.0 | No Relaxation | Nil |
| 15. Arsenic mg/l | 0.01 | No Relaxation | Nil |


Remark- 1. All chemical parameters except pH are in mg/l
 2. Tested Results Relate only to The Samples send by you


22/04/26
 Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2026-2027/
 Copy to:- 1. The Chief Chemist, PHED Raj, Jaipur

Date:

Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur


PRINCIPAL
 Mahaveer Public School
 JAIPUR


Secretary
 Mahaveer Public School